

Change Cracked Cutout

Scenario: Replace cutout, the crew must shed load from the breaker, remove the top side of the cutout with the shotgun while supporting the top of the cutout with the other shotgun. Then roll up jumper and isolate the secondary in H.V. rubber gloves. Replace the cutout, put secondary back in, and put topside on. Climb down. Once both climbers are on the ground, have the groundman put the fuse back in with a long stick and close the fuse with the ring. Time stops when the breaker is turned back on.

Deductions

2-point deductions:

- Breaking minimum approach distance
- Dropping tools or equipment
- Closing fuse not in the ring

10- point deductions:

- Failure to isolate secondary
- Lack of P.P.E.

See score sheet for additional infractions. **Competitors must wear 100% fall protection**

15:00 Mean Time

